

WALLOPS MISSION LAUNCH COMMAND CENTER, IFB NNG15539892R

INDUSTRY QUESTIONS

43. Toilet Compartment Section 10 21 13 para 2.1 specifies HDPE material for Toilet Partitions and Urinal Screens. In para 2.2.1 it specifies HDPE for Toilet Partitions and in para 2.2.2 it specifies solid phenolic for Urinal Screens. Which is this correct??

NASA RESPONSE: HDPE is the preferred material for all partitions. Solid phenolic for the urinal screens is acceptable.

44. Should we include the verbiage under the certification by Offerors regarding Federal Income Tax Filing and Federal Income Tax Violations on a separate sheet or just attach the sheets to the SF1442 Form??

NASA RESPONSE: As stated in provision L.29 of the solicitation, section K provisions shall be completed and submitted with the bid. Method of submission is at the discretion of the offeror.

45. May I find out the status of the Furniture Package for the Mission Launch Command Center at Wallops Island. Has the furniture package been awarded yet? If it has not, has it been put out to bid?

NASA RESPONSE: Outfitting of the Mission Launch Command Center will be conducted by the end user via existing Government contract.